

## EMERGENCY LIGHTING TEST UNIT

- Emergency Lighting Test Switch pre-wired and self contained.
- Performs a 2 hour discharge test on emergency lighting installations.
- Easy to connect to existing circuits.
- Key to initiate discharge test.
- Manual reset to override test.
- Adjustable time delay relay.
- 4 pole 25A contactor.
- Compact design - 130 x 120 x 80mm.
- Complies with AS2293.1-2005.



P/N T-ELTUE



P/N T-ELTUELX

- Electronic Emergency Lighting Test Unit.
- Compact DIN mount design.
- 90 min to 120 min selectable.
- Power-on Indication.
- Timer initiated indication.
- 3 pole 16A (AC1) rated contacts.
- 1 pole 8A contact + aux output for additional contactor.

Cover to suit T-ELTUELX



P/N DA-L4

**TOBIN ELECTRICAL COMPONENTS PTY. LTD.**

2C Brunner Road, Chullora NSW 2190

Phone 02 8713 5200 Fax 02 9790 5211 [www.tobins.com.au](http://www.tobins.com.au)